

2021-14

EDGEWATER PARK SEWERAGE AUTHORITY

**RESOLUTION AUTHORIZING HOOVER PLAZA TO DISCHARGE FROM AN OIL
WATER SEPARATOR TO AUTHORITY SEWER LINE**

WHEREAS, the Edgewater Park Sewerage Authority, a duly constituted public body in the County of Burlington, State of New Jersey (“Authority”).

WHEREAS, the Authority agrees to allow Hoover Plaza to discharge from their Oil and Water separator to the Authorities sewer line in accordance with the requirements outlined as follows:

1. The property owner is responsible for the Maintenance of the Oil and Water Separator per Section V of the WMUA Rates, Rules, and Regulations;
2. the property owner is required to submit documentation that shows that the Oil and Water Separator is cleaned once each calendar year; and
3. the property owner is required to provide laboratory analytical results showing that the Oil and Water Separator is meeting the effluent standard of 10 mg/l on an annual basis.

NOW, THEREFORE BE IT RESOLVED, upon proper motion and vote at a public meeting by the Edgewater Park Sewerage Authority in the County of Burlington, State of New Jersey as follows:

1. The Edgewater Park Sewerage Authority agrees with this course of action

ADOPTED this Resolution on March 10, 2021.

Attest:

Edgewater Park Sewerage Authority



Judith Hall, Chairwoman



Phil Aaronson, Vice Chairman